



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No. : MCPHL/26/2976

Date : 13.08.2026

Ref. No. : SJHS/2026-27/6842	Sample Details	Date & Time
Dated : 05.08.2026	Collected By : Laboratory Staff	
Issued to : The Principal St. John's High School, Sector - 26, Chandigarh.	Collection Date : 10.08.2026	06:30p:m
Location : From School tap of St. John's High School, Sector - 26, Chandigarh.	Received at Lab : 08:30p.m.	
Packing : Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	—	7.70
2	Odour	Agreeable	—	Agreeable
3	Taste	Agreeable	—	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	126
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	84
8	Total Hardness (as CaCO ₃)	<200	mg/l	92
9	Chlorides (as Cl)	<250	mg/l	19.99
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 08/2026-27/336232, dated 06.08.2026, amount Rs.-3300/-

Note:- Water sample is found "POTABLE".

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/-----

Dated : 13.08.2026

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT



Scanned with OKEN Scanner